



As with all high performance commercial condensing boilers with aluminium heat exchangers, it is important to fill and top up the system with water that does not contain a lot of calcium carbonate.

It is prohibited to perform the system filling with rain main water.

Complete water demineralization for system filling and charge is performed with conductivity level being $<10 \text{ Mx/cm}$. Feed water quality has also to fully comply with the parameters given.

Corrosion Inhibitor Epurocet W320 is recommended to be used additionally for boilers with aluminium heat exchange unit.

Inhibitor dose equals to 1,01 for 1 m³ of water.

REVISION LIST:		
NO.	DATE:	REMARKS:

[illegible]

KEYPLAN

PROJECT NAME:	
პროექტის დასახელება:	

PROJECT ADDRESS: Հիմնական տվյալներ:	
CLIENT: Ծածկագիր:	
POSITION: Ծածկագիր:	
ENGINEER: նշանակում:	

DWG REFERENCE:	
DRAWING STATUS:	Issued for Construction

SHEET NO. **A105**
ნახაზის ნომერი:

SHEET DESCRIPTION:
ნახაზის დასახელება:

საქვამდე და ჩილური

REVISION:	PAGE SIZE:	DRAWING SCALE:
	A1	

HVAC Heating/cooling/Ventilation
გათბობა/გაგრილება/ ვენტილაცია